Email: cewwm@bwssb.gov.in

Ph: 080-22945106

ಬೆಂಗಳೂರು ನೀರು ಸರಬರಾಜು ಮತ್ತು ಒಳಚರಂಡಿ ಮಂಡಳಿ

BANGALORE WATER SUPPLY & SEWERAGE BOARD

O/o Chief Engineer(WWM-East), 5th Floor, Cauvery Bhavan, Bangalore-560009.

No. BWSSB/ CE(WWM-E)/ DCE(WWM- E&W)/TA-1/ 1084/2025-26 Date : 21.11.25

ADDENDUM -1

Sub: Work of comprehensive Operation and Maintenance of 15 MLD STP at Yelemallappachetty, 5 MLD ISPS at Sadaramangala and Maintenance of Pumping line of 450mm dia DI pipeline from Sadaramangala ISPS for 3.5kms for the period of 5 years.

Ref: No.BWSSB/CE(WWM-E)/DCE(WWM-E&W)/TA-1/980/2025-26 Dt:28-10-2025

~~*

With reference to the above subject, invitation for this tender was invited vide IFT mentioned in reference letter this Addendum indicates the details of response to the pre bid queries.

Chief Engineer(WWM-E)
BWSSB

Encl: Replies Pre bid Queries

Work of comprehensive Operation and Maintenance of 15 MLD STP at Yelemallappachetty, 5 MLD ISPS at Sadaramangala and Maintenance of Pumping line of 450mm dia DI pipeline from Sadaramangala ISPS for 3.5kms for the period of 5 years

S.N	Section/Clause No	Tender Requirement	Query/clarification Requested	Reply
1	Section 5 Clause 41 (Liquidated Damages)	LD Provisions mentioned under conditions of contract	Bidder request you to kindly confirm the maximum limit of Liquidated damages as the contract data page does not clearly specifiy the cap in the uploaded documents.	Tender Condition Prevails
2	Brief Description of the plant	Treated Effluent Quality Requirements	The bidder requests you to please confirm whether the palnt is currently complying the NGT standards or not	Plant is designed to meet NGT norms with the parameter prescribed in the tender
3	Common Query 3.Qualification of the Tenderer 3.2 b)	The tenderer as prime or lead contractor, in any one year should have satisfactorily completed at least one similar work such as Operation and Maintenance of Sewage Treatment Plant based on Sequencing Batch Reactor (SBR) of value not less than Rs.735.16 lakh.	The amount put to tender is Rs.1470.33 lakhs for 5 years of Operation and Maitenance contract. Hence, the value of cost per Annum is Rs.294.07 lakhs. They requested to consider the per annum cost of Rs.294.07 lakhs for meeting the pre qualification for this tender.	Tender Condition Prevails
4	Common Query 3.Qualification of the Tenderer 3.2 b)	The tenderer should have O&M Experience of only STP of 12 MLD STP based on Tertiary Treatment Unit/Additional Treatment Unit i.e, Disc Filtration/Ultra Filtration Membrane Bio Reactor of minimum One year	We request to consider O&M Experience of only STP of 12 MLD STP based on Sequencing Batch Reactor (SBR) Technology to this condition.	Tender Condition Prevails
5	Tender Document clause No.3.2 e page No.11	e) The Tender should have O&M Experience of 12 MLD STP based on Tertiary Treatment Unit/Additional Treatment Unit/ i.e, Disc Filtration/Ultra Filtration/Membrane Bio Reactor of Minimum one year	Most of the plant will not have Tertiary Treatment unit/Additional Treatment Unit i.e, Disc Filtration/Ultra Filtration Membrane Bio Reactor. Hence We request you to consider to include MOU as Below "The Tenderer or Partner or his nominated sub contractor shall have sucessfully executed, 12 MLD STP based on Tertiary Treatment Unit/Additional Treatment Unit i.e, Disc Filtration/Ultra Filtration Membrane Bio Reactor of minimum one year	Tender Condition Prevails

Addl. Chief Engineer
(WWM-Project-East)
BWSSB

Chief Engineer
(WWM-East)
BWSSB